


440-480 VAC 3 PHASE



CB1=2 AMP TWO POLE CIRCUIT BREAKER
 CB2=2 AMP SINGLE POLE CIRCUIT BREAKER
 DIS=NON FUSED DISCONNECT SWITCH
 DR1=ENTRY DOOR SENSOR SWITCH
 DR2=EXIT DOOR SENSOR SWITCH
 EMO=EMERGENCY STOP SWITCH
 LGT=LED LIGHT FIXTURE
 LK1=24VDC MAGNETIC DOOR LOCK ENTRY
 LK2=24VDC MAGNETIC DOOR LOCK EXIT
 MOT=3HP MOTOR 3500 RPM (7 F.L.A. @ 480 VAC 3 PHASE PER MOTOR)
 TF1=480 VAC - 120 VAC 250VA TRANSFORMER
 TF2=120VAC - 24 VDC 2 AMP POWER SUPPLY



PO Box 427
 Rancho Cucamonga, CA 91729-0427
 Voice: (800) 913-0054
 Fax: (909) 483-1801

Drw#	Title: ELECTRICAL SCHEMATIC
Sheet: 1 OF 1	Project name: