

CP PASS THRU SPECIFICATION FOR SINGLE WALL STAINLESS STEEL CONSTRUCTION

1.0 PURPOSE AND SCOPE

This specification describes a factory fabricated pass thru enclosure to be used for maintaining an air sealed air lock between a Clean Room environment and outside contaminated atmosphere. It shall be designed with simplicity in mind while maintaining an aesthetic appearance.

2.0 CONSTRUCTION

- A. Model CPSS pass thrus shall be constructed of a single wall of 16 gage 304 stainless steel with a #4 brushed finish. All seams have a continuous weld and are ground smooth to match the #4 brushed finish.
- B. The doors for the pass thrus are made of a 304 stainless steel frame door with a #4 brushed finish that has a 0.25" clear tempered glass vision panel.
- C. The trim angle for the pass thru is made from 1.5" x 1.5" 16 gage 304 stainless steel with a #4 brushed finish.
- D. The pass thru does not have a bottom. It sits on the floor and uses the existing flooring.

3.0 Hardware

- A. The pass thru catches are a spring loaded 304 stainless steel device that enables the door to be closed without turning a handle.
- B. The hinges are a lift off stainless steel hinge that enables easy cleaning and replacement.
- C. The seals for the doors are Pemko S88W vinyl bulb gasket.
- D. The mechanical interlock is made from 0.25" stainless steel all tread with polished aluminum turn buckles on each end that are turned 90 degrees from each other so that when one side has the buckle clear of the door the opposite side blocks the door.

4.0 Options

- A. Electric interlock system
 - 1. The pass thru door locks are a 24VDC magnetic lock
 - 2. Each door has a magnetic sensor switch that determines the status of the door.
 - 3. The pass thru shall have a flush mounted access panel in the top of the pass thru with a 24VDC power supply and terminal blocks.
- B. Fan filter module
 - 1. There shall be a cutout in the top of the pass thru with a 99.99% @ .3 micron HEPA fan filter unit bolted to the top. There shall be perforated openings in the side wall of the pass thru on the dirty side.
 - 2. The fan filter shall require a 120 VAC power connection.
- C. Shelf
 - 1. The shelf shall be constructed of 304 stainless steel with a #4 brushed finish.
 - 2. The shelf is supported by 4 304 stainless steel shelf standards with stainless steel clips.
 - 3. Each shelf will support up to 25 pounds each.